

Work Instructions



Adjustment aid for CMC-TC PUII and LCP Plus in conjunction with the new automatic door control unit 7320.790

1. Adjustment of an automatic door opening for an alarm

Concerns: CMC-TC PUII and LCP Plus

The web page of the CMC-TC system can be used to invoke a "**combination**" alarm link function for the automatic door control unit.

For example, it is possible to cause the door to open when the temperature is too high.

Important: If other door systems should be opened for the same alarm, the "**combination**" used for the second, third, etc., time can no longer be set or programmed with too-high temperature.

Rather than querying the temperature sensor, the status of the first door system must be queried, similarly the status of the second door system for the third "**combination**", etc.

Outlook: The software update available in August 2009 will permit the arbitrary use of the alarms for different "**combinations**".

2. Opening the door using the LCP Plus display in conjunction with automatic door opening

Concerns: LCP Plus

The LCD Plus display can be used to open (command: Open) and close (command: Close) the automatic door control unit doors.

Important: The "**delay time**" can be set in the LCP Plus web page for the automatic door control unit. This "**delay time**" has "0" as default setting and must not be changed because otherwise the display operation control functions could change their logic.

Outlook: The software update available in May 2009 will provide a display user interface with a new layout with which the "**delay time**" can be used to automatically activate the automatic door control unit magnets.