

CMC-TC voltage monitor with IEC-switched output **DK 7320.610**

Attention!

Please note that the voltage monitor with IEC-switched output only operates correctly in conjunction with the latest software version. Specific details can be found in the following:

Processing Unit (DK 7320.100) with software version 1.1 or higher!

A free-of-charge software update from version 1.0 to 1.1 as well as the relevant instructions is now available from our homepage www.rittal.de.

I/O Unit (DK 7320.210) with software version 1.1 or higher!

Please send the I/O unit together with this information notice stating the old software version and the application purpose to your RITTAL-distributor. RITTAL will then immediately send you a new I/O unit together with the current software.

This procedure necessitates the integration of certain CMC-TC 2003 product innovations in previously purchased CMC-TC installations. We ask for your understanding regarding this matter.

Your RITTAL IT-team

Address: Rittal GmbH & Co. KG / Auf dem Stützelberg / D-35745 Herborn, Germany,
Tel: +49 (0)2772-505-0 Fax: +49 (0)2772-505-2319 / Email: Info@rittal.de / Internet: <http://www.rittal.com>

A30637 00 IT 75