

Guideline to the Software Update for the CMC-TC Processing Unit DK 7320.100

A few introductory remarks: The following description of the SW Update transmission is based on the FTP protocol. Requirements: the FTP must be installed and implemented on the PC and the FTP function of the CMC-TC system must be activated. The FTP function is activated with the help of the hyper-terminal or Telnet in the 1.1 Network Configuration menu of the processing unit – input Enabled.

In addition, the installation routine requires the FTP passwords of the factory settings; if necessary for the purpose of the update, you reset the latter via hyper-terminal or Telnet to:

Username: cmc

Password: cmc.

Note: As a result of the update, the previous configuration settings are replaced by the factory settings overriding the former.

1. Download the current SW version of the RITTAL-Homepage www.cmc-tc.com and copy to the hard disk memory.

2. Unzip the file downloaded by WINZIP to your hard disk in a separate directory.

Please note that the file is extracted by indicating the destination and is not copied directly into the main directory of the hard disc, e.g. C:

3. Starting the Processing Unit!

Power up, plug in the network connector and tune the IP address and Subnet mask to your network. Make a note of the processing unit IP address.

4. Open the MS DOS input screen via the Windows Start-Button, go to the directory in question and input the following command: update 192.168.0.190, the IP address having to be identical with the IP address of your processing unit.

5. Acknowledging the command input with the ENTER key, your processing unit will now be updated to the latest SW software version.

6. Having completed the above steps you are requested by the system to reboot the computer.

You either boot the processing unit comfortably via the built-in software function in Telnet under menu item 1.1.F Activate Actual Values, or you briefly interrupt the power supply to the processing unit by pulling the power plug and subsequently connecting it again.

7. By opening the menu item 4 Info page, you can make sure that the new software version has been implemented.

Your RITTAL-IT-Team